

11-7-4: WATER MAINS:

Both "off site" and "on site" water mains of not less than six inches (6") in diameter shall be installed in such a way that each lot can be served therefrom. (Ord. 6-18-81C, 6-18-1981)