

10-8C-7: SPECIAL PROVISIONS:

All buildings made of combustible material shall be located at least twenty feet (20') apart.
(Ord. 2005-02, 4-12-2005)